

**Minutes of meeting 8<sup>th</sup> Meeting of the re-constituted EAC (Thermal Power) was held on 24<sup>th</sup> July, 2017**

EC Amendment Compliance report of :-

**(8.6) 2x800 MW (Stage-I) Gadawara Super Thermal Power Project near villages Gangai, Umaraiya, Mehrakheda, Chorbarheta, Dongergaon and Kudari, in Gadawara Tehsil, Narsinghpur Distt. in Madhya Pradesh by M/s NTPC Ltd.-reg. amendment in EC. (File No: J-13012/125/2009-IA.II(T)& Online no: IA/MP/THE/17134/2013).**

(8.6.3) Committee after detailed deliberations, **recommended for change in coal source from Talaipalli block to Pakri Barwadih coal block and for transportation of 8 MTPA coal by road for a distance of 15 km till December, 2018** subject to following additional conditions:

S. No.	Compliance	Status
1	Road repair and maintenance is to be carried out by NTPC.	Shall be complied, whereas required
2	Trucks shall be covered with tarpaulin and properly stamped to ensure that tarpaulin is properly tied with the help of rope and truck shall be fully covered so that there is no spillage of coal and/or emission of dust during transportation.	Shall be complied. This condition has been incorporated in letter of award to the transporter / contract.
3	Continuous water sprinkling, sweeping and dust control measures shall be carried out through out the road for minimising the air pollution.	Shall be complied, during the transportation of Coal from coal siding to plant.
4	Plantation shall be carried out along side of the road for noise attenuation and control of air borne dust.	It is being complied and in progress.
5	Plantation shall also be carried out on the banks of Sangam confluence of Shakkar nadi and Narmada nadi.	Contract proposal for the same is being initiated and plantation shall be carried out .